



HAL
open science

Vector intensity measures for a more accurate reliability assessment of NPP sub-systems

Pierre Gehl, Jeremy Rohmer

► To cite this version:

Pierre Gehl, Jeremy Rohmer. Vector intensity measures for a more accurate reliability assessment of NPP sub-systems. International Conference on Technological Innovations in Nuclear Civil Engineering , Aug 2018, Saclay, France. hal-01832855v1

HAL Id: hal-01832855

<https://brgm.hal.science/hal-01832855v1>

Submitted on 9 Jul 2018 (v1), last revised 19 Mar 2019 (v2)

HAL is a multi-disciplinary open access archive for the deposit and dissemination of scientific research documents, whether they are published or not. The documents may come from teaching and research institutions in France or abroad, or from public or private research centers.

L'archive ouverte pluridisciplinaire **HAL**, est destinée au dépôt et à la diffusion de documents scientifiques de niveau recherche, publiés ou non, émanant des établissements d'enseignement et de recherche français ou étrangers, des laboratoires publics ou privés.

Vector intensity measures for a more accurate reliability assessment of NPP sub-systems

P. Gehl, J. Rohmer

Within the European-funded H2020 NARSIS project (New Approach to Reactor Safety ImprovementS, <http://narsis.brgm.fr>), one of the main challenges pertains to the development of innovative methods for the numerical derivation of fragility function for systems, structures or components (SSCs) within nuclear power plants (NPPs). In this context, the present study investigates the effect of integrating secondary seismic intensity measures when assessing the reliability of SSCs, with the objective of better identifying or even reducing the uncertainties due to record-to-record variability. While such an approach has already been applied to common reinforced-concrete or masonry buildings in previous studies, it is proposed here to consider an industrial structure containing a set of components at various locations of the building. We propose to treat the problem of station blackout following an earthquake (an accident event which is of primary importance as exemplified by the Fukushima Dai-Ichi event). Here the internal equipment is supposed to perform a given function (e.g., generation of emergency on-site power) and it may therefore be considered as a sub-system, for which a functionality assessment may be required within a probabilistic safety analysis.

The studied sub-system comprises various types of components, whose failure modes are susceptible to either floor acceleration spectra or inter-story drift (e.g., failure of anchor bolts, excessive stress in pipeline segments, etc.). Such engineering demand parameters at various floor locations are not evenly correlated with the same intensity measures (e.g., spectral accelerations at different periods), thus highlighting the need for vector intensity measures that are able to capture a wide range of potential failure modes. Finally, the vector-based fragility functions derived at the component level are assembled in order to quantify the probability of the sub-system losing its function, for various levels of seismic loading. The statistical dependence between component failure events is taken into account thanks to the matrix-based system reliability method. A parametric study is then performed in order to evaluate the sensitivity of the sub-system's reliability with respect to various assumptions (e.g., correlation between failure events, correlation between intensity measures, etc.).