

Multidisciplinary subsurface monitoring for a better understanding of Soil Aquifer Treatment capacity applied on coastal operational wastewater treatment plant (Agon-Coutainville, France)

Géraldine Picot-Colbeaux, Marie Pettenati, Coralie Soulier, Harrie Besselink, Matthieu Baïsset, Jcep Appels, Anne Togola, Loïc Thomas, Nicolas Devau, Frédéric Mathurin

▶ To cite this version:

Géraldine Picot-Colbeaux, Marie Pettenati, Coralie Soulier, Harrie Besselink, Matthieu Baïsset, et al.. Multidisciplinary subsurface monitoring for a better understanding of Soil Aquifer Treatment capacity applied on coastal operational wastewater treatment plant (Agon-Coutainville, France). ISMAR 10 -The 10th International Symposium on Managed Aquifer Recharge, May 2019, Madrid, Spain. hal-02106967

HAL Id: hal-02106967 https://brgm.hal.science/hal-02106967

Submitted on 23 Apr 2019

HAL is a multi-disciplinary open access archive for the deposit and dissemination of scientific research documents, whether they are published or not. The documents may come from teaching and research institutions in France or abroad, or from public or private research centers. L'archive ouverte pluridisciplinaire **HAL**, est destinée au dépôt et à la diffusion de documents scientifiques de niveau recherche, publiés ou non, émanant des établissements d'enseignement et de recherche français ou étrangers, des laboratoires publics ou privés.



Multidisciplinary subsurface monitoring for a better understanding of Soil Aquifer Treatment capacity applied on coastal operational wastewater treatment plant (Agon-Coutainville, France)

Picot-Colbeaux, Géraldine¹; Pettenati, Marie¹; Soulier, Coralie¹; Besselink, Harrie⁵; Baïsset, Matthieu³; Appels, Joep⁴; Togola, Anne¹; Thomas, Loic²; Devau, Nicolas¹; Mathurin, Frédéric¹

¹BRGM, Orléans, France
²GeoHYD (Anteagroup), Olivet France
³Imageau (SAUR), Montpellier, France
⁴MicroLan, Waalwijk, Netherlands
⁵BDS, Amsterdam, Netherlands

g.picot@brgm.fr

KEY WORDS SAT, MAR, coastal aquifer, natural/engineered water treatment, reuse

ABSTRACT

Unconfined coastal aguifers are potentially subject to both saline intrusion near the seashore and over discharge of treated wastewater in the surficial environment during the tourist season. In Agon-Coutainville (Normandy, France), managed aquifer recharge (MAR) system, combined with Soil Aquifer Treatment (SAT), was integrated as part of the full-scale operational wastewater treatment plant. Such integrated natural/engineered water treatment system ensure the sustainability of the seaside activities (seafood production, beach) and locally supply freshwater for the irrigational needs of the golf course. Concerning the MAR system, the secondary treated wastewater is infiltrated alternatively into three natural reed bed areas before reaching the sand dune aquifer and thus to enhance the quantity of freshwater in the aquifer. Treated wastewater potentially contains various compounds (chemical, virus, pathogen) which can, however, affect the groundwater quality. Nevertheless, some of these compounds are partly removed, during the SAT. To assess performance and efficiency of the integrated system in the natural environment, we have designed and performed an innovating and multidisciplinary monitoring dedicated to 1) spatial evolution of the freshwater generating by the MAR system, 2) mean residence time of water during SAT and 3) potential reactivity occurring during SAT. Spatial field campaigns and tracer tests were conducted by associating classical and innovative approaches including physico-chemical measurements and quantitative analyses, non target analysis for screening organic compounds, ecotoxicological bioassavs, online biomonitoring BACTcontrol® system to detect fecal contamination and online system monitoring device dedicated to saline intrusion. Results show that the MAR system provides a freshwater barrier in the aquifer which is seasonally affected by saline intrusion. A part of the aquifer is assessed for freshwater potential production regardless of the natural and anthropogenic recharge. SAT mean residence time is around two weeks that allows SAT reactivity and thus increases quality of the pumped groundwater. This novel subsurface monitoring provides a better understanding of the SAT capacity to enhance the quantity of freshwater and improve its quality.